

Fire Service Headquarters  
'Gokulam', Pattom P.O.,  
Thiruvananthapuram-4

No: G1- 7012/2000

Dated: 27-7-2000


C E R T I F I C A T E

The plan of a two storeyed (G+1) school building in Survey No: 31 ward 13 in Palayad Village in Maniyoor Panchayat proposed to be constructed by Secretary, Amritha Public School, Badagara Pin: 673101 was verified by the Scrutiny committee, Fire Services HQrs., Thiruvananthapuram on 26-7-2000. They recommended the issue of No Objection Certificate in respect of the plan submitted by the applicant subject to the following conditions.

1. All firefighting arrangements should be made as per the enclosed attested plan.

2. All the staircases should reach upto the roof top.

2. Under my seal and authority a No Objection Certificate is issued for the proposed construction of a two storeyed school building in the above mentioned stea dn survey No. A fresh No Objection Certificate should be obtained from this department after completion and before occupation of the building.

  
DIRECTOR (TECHNICAL)  
For Commandant General  
Fire Services

To

The Secretary  
Amritha Public School  
Badagara Pin: 673101

Copy to: The Party  
The Asst. Divisional Officer, Fire Station, Kozhikode